



Product Service

# CERTIFICATE

No. Z2 121422 0001 Rev. 00

**Holder of Certificate:** **JUST SOLAR GROUP LIMITED**

No.66 Miaoqing Road, Minhang District  
201706 Shanghai  
PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:**



**Product:**

**Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 701262312301-00

**Valid until:** 2028-03-04

**Date,** 2023-06-09

( Zhulin Zhang )

# CERTIFICATE

No. Z2 121422 0001 Rev. 00

## Model(s):

JST-FCMH-xxxW (xxx=640-675, in steps of 5)  
JST-FDMH-xxxW (xxx=575-615, in steps of 5)  
JST-FEMH-xxxW (xxx=520-560, in steps of 5)  
JST-FGMH-xxxW (xxx=475-510, in steps of 5)  
JST-FKMH-xxxW (xxx=375-410, in steps of 5)  
JST-EBMH-xxxW (xxx=520-555, in steps of 5)  
JST-EBMH-xxxW (xxx=560-580, in steps of 5)  
JST-EDMH-xxxW (xxx=430-465, in steps of 5)  
JST-EDMH-xxxW (xxx=470-480, in steps of 5)  
JST-EFMH-xxxW (xxx=390-415, in steps of 5)  
JST-EFMH-xxxW (xxx=420-435, in steps of 5)  
JST-DBMH-xxxW (xxx=410-460, in steps of 5)  
JST-DDMH-xxxW (xxx=335-385, in steps of 5)  
xxx is standing for rated output power at STC.

## Parameters:

Construction: Framed, with Junction box,  
Cable and Connectors.  
Test Laboratory: Changzhou HuaYang Inspection  
and Testing Technology Co., Ltd.  
NO.8 Lanxiang Road,  
Wujin Economic Development Zone,  
Changzhou, Jiangsu, China  
Safety Class: Class II  
Maximum System Voltage: 1500 V DC  
Fire Safety Class: Class C according to UL790

## Tested according to:

IEC 61215-1:2016  
IEC 61215-1-1:2016  
IEC 61215-2:2016  
IEC 61730-1:2016  
IEC 61730-2:2016  
EN 61215-1:2016  
EN 61215-1-1:2016  
EN 61215-2:2017  
EN IEC 61730-1:2018  
EN IEC 61730-1:2018/AC:2018-06  
EN IEC 61730-2:2018  
EN IEC 61730-2:2018/AC:2018-06